



County of Riverside  
**DEPARTMENT OF ENVIRONMENTAL HEALTH**

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NON COMPLIANCE – WATER SYSTEM NO. 3301631  
NO. 05\_63\_16C\_020**

Re: Skyland Ranch Camp  
System No. 3301631

Date: September 14, 2016

To: Girls Scouts of San Geronio Council  
1751 Plum Ln.  
Redlands, CA 92374

**VIOLATION**

The Department of Environmental Health (Department), hereby issues a citation to Skyland Ranch Camp for the following violations:

1. Title 22 of the California Code of Regulations (CCR), Section 64426.1 (b) (4). Specifically, Skyland Ranch Camp failed the Total Coliform Maximum Contaminant Level (MCL) during the months of July 2016. For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or any repeat sample is fecal coliform-positive or E.coli-positive; or any repeat sample following a fecal coliform-positive or E.coli-positive routine sample is total coliform-positive.

**CHRONOLOGY OF EVENTS**

On July 7th, 2016, Ron Sobala collected one routine samples from the distribution system (Duncan Lodge). On July 9<sup>th</sup>, 2016 Mr. Sobala was notified by Babcock Laboratories that the routine sample was total coliform present/E.coli absent. On July 9<sup>th</sup>, 2016 Mr. Sabola collected three resamples (FOS Building, Ranger residence and Duncan Lodge.) On July 10<sup>th</sup>, 2016 Mr. Sobala was notified by Babcock Laboratories that the resamples were total coliform present and E. coli absent. On July 11<sup>th</sup>, 2016. Mr. Sabola notified this Department of incident. He consulted with Jackie Jones in the Indio office. He stated that he had sanitized the system and would be resampling. Ms. Jones instructed him to sample the wells and reviewed resampling requirements. On July 11<sup>th</sup> Mr. Sobala collected a sample at each well (#1 and #2) as per lab report dated July 14, 2016 both samples were total coliform and E. coli absent. On July 13, 2016 Mr. Sobala collected three resamples (ranger house, FOS building and Ranger house) as per laboratory report dated 7/18/2016 all samples were total coliform and E. coli absent. On July 25, 2016 Mr. Sobala collected a special sample from Duncan lodge. Laboratory report dated July 25, 2016 reported sample to be total coliform and E. coli absent.

## DIRECTIVES

All consumers served by this water system must be notified of this violation, as required in Section 64426.1 (c). The notice must be posted in conspicuous locations throughout the area served by the water system for no less than 7 days.

Your public water system must be maintained so that the total coliform MCL is not violated. Consult with this Department, or other qualified water professional, to correct and/or prevent reoccurrence of this violation.

The required coliform bacteria follow-up sampling to an unsatisfactory routine sample is described below. This must be completed each and every time that a routine coliform bacteria sampling is unsatisfactory.

1. Within 24 hours of being notified of an unsatisfactory coliform bacteria result by your laboratory, collect four resamples. If you are unable to collect the resamples within 24 hours, contact this Department. Collect the resamples at the sample tap where the unsatisfactory sample was taken, an upstream sample within 5 service connections of the unsatisfactory site, a downstream sample within 5 service connections of the unsatisfactory site, and a sample at the source(s) of water for the distribution system. All active wells must be sampled. If the direction of flow in the distribution system is not known, or if the distribution system is quite small, contact this Department for guidance.
2. If any of the resamples are unsatisfactory, additional sets of resamples must be taken. Contact this Department for guidance.
3. In the month following the unsatisfactory sample collect five coliform bacteria samples.  
Requirement met on 8/17/2016

## FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

If you have any questions, please contact Daisy Ciudad Real at (951) 955-8980.



Daisy Ciudad Real, MPH, REHS

CERTIFIED MAIL: 7015 0640 0006 0767 2795